


STANDARD REINFORCED PIER

PIER	FOOTING DIMENSIONS AND REINFORCEMENT					PIER REINFORCEMENT				
	A	B	C	NO. OF #5 BARS EA. DIRECTION		BARS M	BARS N		X	Y
H	3'-0"	6'-0"	1'-3"	5	5	NONE	NO.	SIZE	LENGTH	
0'-4"	3'-0"	6'-0"	1'-3"	5	5	NONE	6	#6	H + 2' - 0"	1'-9"
5'	3'-2"	6'-2"	1'-3"	5	5	NONE	6	#6	H + 2' - 0"	1'-9"
6'	3'-4"	6'-4"	1'-3"	5	5	#6	6	#6	5'-4"	1'-9"
7'	3'-6"	6'-6"	1'-3"	5	5	#6	6	#6	5'-4"	1'-9"
8'	3'-8"	6'-8"	1'-3"	5	5	#6	6	#6	5'-4"	1'-9"
9'	3'-10"	6'-10"	1'-3"	5	5	#6	6	#6	5'-4"	1'-9"
10'	4'-0"	7'-0"	1'-3"	5	5	#6	6	#6	5'-4"	1'-9"
11'	4'-2"	7'-2"	1'-3"	5	5	#6	6	#6	5'-4"	1'-9"
12'	4'-4"	7'-4"	1'-3"	5	5	#6	6	#6	5'-4"	1'-9"
13'	4'-6"	7'-6"	1'-6"	5	5	#6	6	#6	5'-7"	1'-9"
14'	4'-8"	7'-8"	1'-6"	5	5	#6	6	#6	5'-7"	1'-9"
15'	4'-10"	7'-10"	1'-6"	6	6	#6	6	#6	5'-7"	1'-9"
16'	5'-0"	8'-0"	1'-6"	6	6	#6	6	#6	5'-7"	1'-9"
17'	5'-2"	8'-2"	1'-6"	6	6	#6	6	#6	5'-7"	1'-9"
18'	5'-4"	8'-4"	1'-6"	7	7	#6	6	#6	5'-7"	1'-9"
19'	5'-6"	8'-6"	1'-6"	7	7	#6	6	#6	5'-7"	1'-9"
20'	5'-8"	8'-8"	1'-6"	8	8	#6	6	#6	5'-7"	1'-9"
21'	5'-10"	8'-10"	1'-6"	8	8	#6	6	#6	5'-7"	1'-9"
22'	6'-0"	9'-0"	1'-6"	9	9	#6	6	#6	6'-0"	1'-9"
23'	6'-2"	9'-2"	1'-6"	9	9	#6	6	#6	6'-0"	1'-9"
24'	6'-4"	9'-4"	1'-6"	10	10	#6	6	#6	6'-0"	1'-9"
25'	6'-6"	9'-6"	1'-6"	10	10	#6	6	#6	6'-0"	1'-9"
26'	6'-8"	9'-8"	1'-6"	11	11	#6	6	#6	6'-0"	1'-9"
27'	6'-10"	9'-10"	1'-6"	11	11	#6	6	#6	6'-0"	1'-9"
28'	7'-0"	10'-0"	1'-6"	12	12	#6	6	#6	6'-0"	1'-9"

BARS L	H	NO.-SIZE-LENGTH
	0'-4"	NONE
	4'-28"	2 #6

FULTON COUNTY STANDARD DETAIL 406  
CONCRETE PIER AND FOOTING DETAIL

DATE	REVISIONS	DATE	REVISIONS	DWG./DRN/CHKD. REB	APPROVED: REW	DATE:	FULTON COUNTY	FULTON COUNTY PUBLIC WORKS	DRAWING NO.
8/08	NRR					12-2-05		141 PRYOR ST. ATLANTA, GA. 30303	406
								404-612-7400 FAX: 404-224-0498	