



Department of Purchasing

Felicia Strong-Whitaker, CPPO
Director

Suite 1168
130 Peachtree Street, S.W.
Atlanta, GA 30303
www.fultoncountyga.gov

Main: (404) 612-5800

April 15, 2016

Re: 16FB102296C, Replacing and Upgrading BAS in Darnell Senior Center

Dear Bidders:

Attached is one (1) copy of Addendum 1, hereby made a part of the above referenced Quote.

Except as provided herein, all terms and conditions in the Quote referenced above remain unchanged and in full force and effect.

Sincerely,

Felicia Brooks
Procurement Officer

**16FB102296C, Replacing and Upgrading BAS in Darnell Senior Center
Addendum No. 1
Page Two**

This Addendum forms a part of the contract documents and **modifies** the original Quote documents as noted below:

- Attached Question(s) submitted for clarification
- **The RFQ due date and time has been extended to April 19, 2016, 2:00 PM**

ACKNOWLEDGEMENT OF ADDENDUM NO. 1

The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the proposal package to the Department of Purchasing & Contract Compliance, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by the Quote due date and time **April 19, 2016, 2:00 P.M.**

This is to acknowledge receipt of Addendum No. 1, _____ day of _____, 20__.

Legal Name of Bidder

Signature of Authorized Representative

Title

Attachment#1

Question(s) submitted for Clarification

Question #1: The county listed 20 VAV Boxes. There are 27 VAV Boxes on the existing graphics. What number of VAV boxes do you want us to include? If not all, which ones would you like include?

Answer: Yes please bid on the 27 van boxes

Question #2: The county listed 2 variable speed drives to be integrated. There are 4 VFDs onsite. What number of VFDs do you want integrated? If not all, which ones would you like include?

Answer: Please integrate all VFD drives

Question #3: For the hot water heaters, freezers, and coolers there are 5 sensors listed. To confirm that is to include 1 for the main hot water boiler in north mechanical room, 1 for the walk-in freezer and 1 for the refrigerator across the hall from the north mechanical room, 1 for the domestic boiler in south mechanical room and 1 for the refrigerator across the hall from south mechanical room. Please also confirm if a strap on temperature sensor is acceptable, or if a well sensor is required for the hot water temperature.

Answer: A well secured durable sensor is acceptable. If the sensor meets this requirement it should be fine.