



## Department of Purchasing & Contract Compliance

Felicia Strong-Whitaker, Director

Date: **April 14, 2016**

### Re: **16CT101995A Inspection and Cleaning of Water Storage Tanks**

Dear Quoter(s):

Attached is one (1) copy of Addendum 1, hereby made a part of the above referenced **16CT101995A Inspection and Cleaning of Water Storage Tanks**. Except as provided herein, all terms and conditions in quote referenced above remains unchanged and in full force and effect.

Sincerely,

*Carolyn Towns*

Carolyn Towns  
Procurement Officer

Winner 2000 - 2009 Achievement of Excellence in  
Procurement Award • National Purchasing Institute



## **16CT101995A Inspection and Cleaning of Water Storage Tanks**

Addendum No. 1

Page Two

This Addendum forms a part of the contract documents and modifies the original quote documents as noted below:

- **The following changes are being made:**
- **Closing date had not change from Friday, April 15, 2016 at 2:00p.m. Legal local prevailing time.**
- **All questions submitted for clarification are listed on the attachment.**

**ACKNOWLEDGEMENT OF ADDENDUM NO. 1**


- The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the proposal package to the Purchasing Department, Fulton County Public Safety Building, and 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by the quote due date and time **Friday, April 15, 2016 at 2:00P.M. Legal local prevailing time.**

This is to acknowledge receipt of Addendum No. 1, \_\_\_\_\_ day of \_\_\_\_\_, 2016.

\_\_\_\_\_  
Legal Name of Bidder

\_\_\_\_\_  
Signature of Authorized Representative

\_\_\_\_\_  
Title



**Attachment:**

**Question:** 1. Is the 60 days for cleaning four (4) tanks only or all eight (8) tanks?

**Answer:** - All 8 tanks.

**Question:** 2. Please clarify item 3 under term of agreement stating “the term of agreement is for 12 months from issuance of purchase order” with question 1.

**Answer:** The contract shall be in effect for 12 months as a standard purchase order but the work shall be completed within 60 days.

**Question:** 4. Is a local business license is required or not?

**Answer:** - No.

**Question:** 4. What are the tank dimensions (height, diameter, length, width, depth)?

**Answer:** – **See table below.**

**Question:** 5. When was the last time that each of the tanks was cleaned and inspected?

**Answer:** – **See table below.**

**Question:** 6. Will the County provide support for the dive teams so that work could be carried out on weekends?

**Answer:** – No, Work will not be supported or allowed on weekends.

**Question:** 7. Is there a hardened material or an oil film on the surface?

**Answer:** - Water surfaces have not been observed since last cleaning but no such conditions have been observed to exist in the past.

**Question:** 8. Do the ground storage tanks have baffles?

**Answer:** - No.

**Question:** 9. When exercising water tank valves will a Fulton County employee be present and be responsible for operating?

**Answer:** - Yes

| Tank ID            | Address                                  | Diameter (Feet) | Full Water Depth (Feet) | Top Height From Ground (feet) | Date Cleaned |
|--------------------|--|-----------------|-------------------------|-------------------------------|--------------|
| Alpharetta #1      | 3450 Preston Ridge Rd Alpharetta, Ga.    | 70              | 40                      | 50                            | 3/20/2008    |
| Alpharetta #2      | 3450 Preston Ridge Rd Alpharetta, Ga.    | 95              | 40                      | 50                            | 3/20/2008    |
| Freemanville Rd    | 16300 Freemanville Road, Milton, Ga      | 122             | 45                      | 44                            | 3/18/2008    |
| Pritchard Mountain | 16300 Freemanville Road, Milton, Ga.     | 50              | 35                      | 160                           | Constr 2009  |
| Hembree Rd #1      | 272 Hembree Rd, Roswell, Ga              | 35              | 35                      | 135                           | 3/22/2008    |
| Hembree Rd #2      | 272 Hembree Rd, Roswell, Ga              | 70              | 35                      | 135                           | 3/22/2008    |
| Jones Bridge Rd #1 | 10735 Jones Bridge Rd, John's Creek, Ga. | 50              | 38                      | 150                           | 3/30/2011    |
| Jones Bridge Rd #2 | 10735 Jones Bridge Rd, John's Creek, Ga. | 65              | 38                      | 150                           | 3/31/2011    |

Winner 2000 - 2009 Achievement of Excellence in Procurement Award • National Purchasing Institute

