



July 28, 2016

**Re: 16ITB103233C-GS Generator System Maintenance and Repair Services**

Dear Bidders:

Attached is one (1) copy of **Addendum No. 3, 16ITB103233C-GS Generator System Maintenance and Repair Services**, hereby made a part of the above-referenced Request for ITB - Service.

Except as provided herein, all terms and conditions in the RFB referenced above remain unchanged and in full force and effect.

Sincerely,

*Gertis Strozier*

Gertis Strozier  
Assistant Purchasing Agent

**16ITB103233C-GS Generator System Maintenance and Repair Services  
Addendum No. 3**

This Addendum forms a part of the contract documents and **modifies** the original ITB documents as noted below:

1. You are asking for Air Filters to be replaced on all NG units. Can you specify which units are NG? – The sites that uses natural gas are shown with \*\*\* markings in the specification sheet.
2. Can you provide unit info so that the correct costs can be put in for Belt, Spark Plug and Air Filter replacements. Or can all this be made to be done on a T&M basis when a quote is provided to the county? – The specification sheet should provide sufficient information about the parts needed or can be collected from the manufacturers. Therefore doing this work on a T&M basis cannot be accepted.
3. **Specification of Stand-by Generator Engines**

| Building Name                              | Brand                | Manufacturer   | Model Number       | Serial Number  |
|--|----------------------|----------------|--------------------|----------------|
| FCGC - Midrise Building                    | CAT<br>5B4500046     | CATERPILLAR    | SR-4               | 5NAO5917       |
| FCGC - Midrise Building                    | CAT<br>SR47CHO5      | CATERPILLAR    | SR-4               | 5UA0105        |
| FCGC - Public Safety Building              | CAT<br>SR47C8892     | CATERPILLAR    | 5 YF 0029          | 9Y3135         |
| Justice Tower - Was Justice Center Tower   | CAT<br>SR47C1610     | CATERPILLAR    | 3512 SR-4          | 6PA01521       |
| Juvenile Justice Center                    |                      | CATERPILLAR    | SR4                | AFK00353       |
| WROC, 11575 Maxwell Road, Alpharetta       | GM 81550 - GA5       | KOHLER         | 12V2000G85 - T8    | 5352011647     |
| Central Maintenance Facility               | CUMMINS<br>GBT59GC   | CUMMINS        | 6BT 5.9-BC         | 198185         |
| Auburn Avenue Research Library             | CUMMINS              | CUMMINS        | QSB7 – G5 NR3      | 73912215       |
| Fire Station #5, Pine Ridge                | GENERAC<br>93A01121S | GENERAC        | 93401121-8         | 2006372        |
| Fire Station #17, Cedar Grove              | ONAN                 | ONAN           | 30.0DLG-15R/24845L | F82062270<br>6 |
| Fire Station #15, Cedar Grove Rd, Fairburn | GENERAC              | GENERAC        | 5386280200         | 2083580        |
| FCPD Tactical Command, 3955 MLK Road       | GENERAC              | GENERAC        | SD0080GG174        | 160912         |
| Homeless Shelter                           | KATO                 | KATO           | 125SX9E            | 77076          |
| Center for Rehabilitative Services         | GENERAC              | GENERAC        | 9706-0             | 32067963       |
| Fire Station 13, Plummer Road              | KOHLER               | KOHLER         | 30RZ62             | 107835         |
| Fire Station #23, Cascade                  | KOHLER/SPEC TRUM     | DETROIT DIESEL | 70GS60             | 383037         |
| H.J.C Bowden Senior                        | KOHLER               | KOHLER         | 350REOZVC          | 2127732        |

**16ITB103233C-GS Generator System Maintenance and Repair Services  
Addendum No. 3**

| <b>Building Name</b>                             | <b>Brand</b>         | <b>Manufacturer</b> | <b>Model Number</b>     | <b>Serial Number</b>    |
|--|----------------------|---------------------|-------------------------|-------------------------|
| Multipurpose Facility                            |                      |                     |                         |                         |
| Dorothy C. Benson Senior Multipurpose Center     | KOHLER               | KOHLER              | 350REOZDD               |                         |
| Harriett G. Darnell Senior Multipurpose Facility | KOHLER               | KOHLER              | 400REOZDD               | 2176011                 |
| Helene S. Mills Senior Multipurpose Facility     | KOHLER               | KOHLER              | 450REOZDD               | 2186776                 |
| Adamsville Health Center ***                     | KOHLER 40            | KOHLER              | 40REZG                  | 3034862                 |
| Central Library                                  | ONAN<br>125QDTD15R   | ONAN                | 125 DYA-15R-<br>7707F   | J770274744              |
| D. A. Pearson Maintenance Complex, Bldg. B       | 120/208 3<br>PHASE   | ONAN                | 150RDIC 4XR<br>14585 AB | 52884<br>18659          |
| FAA Building, 3977 Aviation Circle               | ONAN                 | ONAN                | 25DKAF                  | D96060464<br>9          |
| Fire Station #19, Charlie Brown Airport          | ONAN<br>100CCKB3CR   | ONAN                | 10.0CCKB-<br>JCF1319GE  | DBZD88306<br>1          |
| North Fulton Service Center                      | ONAN<br>450EM15R     | ONAN                | 45.0 EM-<br>15R/15543F  | 1274906408              |
| Fire Station #11, Fulton Industrial              | ONAN<br>50BGA30R     | ONAN                | 5.0BGA-<br>3CR/160040   | E81356930<br>4          |
| Fire Station #3, Cliftondale                     | ONAN<br>20OES152     | ONAN                | 20.OES-<br>15R/241688   | J370935997              |
| South Fulton Service Center                      | ONAN<br>45OEM15R     | ONAN                | 45.OEM-15R<br>9346F     | 1274906407              |
| Medical Examiner's Facility ***                  | STAMFORD/CU<br>MMINS | STAMFORD            | GTA 14G2                | K98082712<br>9/11916543 |
| Medical Examiner's Facility ***                  | STAMFORD/CU<br>MMINS | STAMFORD            | GTA 14 G2               | K98082712<br>8/11912082 |
| Fire Station #1, Red Oak                         | PAVID<br>J35DWHB     | PAVID               | G55H1                   | 3575                    |
| Fire Station #7, Midway                          | PAVID<br>J35DWHB     | PAVID               | J35DWH8                 | 3308                    |
| Airport - Administration Building                | KATO<br>75SX9E       | SYNERGY             | 363PSL1607              | LM345886-<br>0301       |

\*\*\*Sites where engines use Natural Gas fuel are shown with superscript \*\*\*

**16ITB103233C-GS Generator System Maintenance and Repair Services  
Addendum No. 3**

**4. REVISED PRICING SHEETS**

**Stand-by Generating Sets Maintenance**

| <b>I No</b> | <b>Building Number</b> | <b>Building Name</b>  | <b>Zone</b> | <b>Generator Size (kW/kVA)</b> | <b>Annual Maintenance Cost</b> |
|-------------|------------------------|---|-------------|--------------------------------|--------------------------------|
| 1           | B613022                | FCGC Midrise Building, 141 Pryor Street   | Central     | 625                            | \$ _____                       |
| 2           | B613022                | FCGC Midrise Building, 141 Pryor Street   | Central     | 956                            | \$ _____                       |
| 3           | B613042                | FCGC Public Safety Building, 130 Peachtree Street   | Central     | 150                            | \$ _____                       |
| 4           | B600052                | Justice Center Tower, 185 Central Avenue  | Central     | 1563                           | \$ _____                       |
| 5           | B506011                | Juvenile Justice Center, 395 Pryor Street, Atlanta GA 30303                                   | Central     | 750                            | \$ _____                       |
| 6           | B501022                | Central Maintenance Facility, 895 Marietta Blvd   | North       | 80                             | \$ _____                       |
| 7           | B703011                | WROC, 11575 Maxwell Road, Alpharetta  | North       | 250                            | \$ _____                       |
| 8           | B451011                | Auburn Ave. Research Library, 101 Auburn Ave  | Central     | 250                            | \$ _____                       |
| 9           | B105023                | Fire Station # 5, 3175 Bethsaida Rd, Fairburn   | South       | 15                             | \$ _____                       |
| 10          | B117013                | Fire Station # 17, 8675 Ridge Rd, Fairburn  | South       | 30                             | \$ _____                       |
| 11          |                        | Fire Station 15, Cedar grove Road, Fairburn   | South       | 250                            | \$ _____                       |
| 12          | B606122                | FCPD Tactical Command Center, 3995 MLK Jr Drive   | North       | 250                            | \$ _____                       |
| 13          | B504032                | Homeless Shelter-Old FC Jail, 1135 Jefferson Street   | North       | 156                            | \$ _____                       |
| 14          | B314012                | Center for Rehabilitative Services, 265, Blvd NE, Atlanta                                     | Central     | 100                            | \$ _____                       |
| 15          | B113012                | Fire Station # 13, 5890 Plummer Road  | South       | 30                             | \$ _____                       |
| 16          | B125013                | Fire Station # 23, 4121 Cascade Road  | South       | 85                             | \$ _____                       |
| 17          | B710013                | HJC Bowden Senior Multi-purpose Center, 2885 Church Street, East Point GA 30344               | South       | 350                            | \$ _____                       |
| 18          | B360012                | Dorothy C. Benson Senior Multipurpose Complex, 6500 Vernon Woods Dr., Sandy Springs, GA 30328 | North       | 350                            | \$ _____                       |
| 19          | B370013                | Harriett G. Darnell Senior Multipurpose Facility, 677 Fairburn Rd. NW, Atlanta GA 30331       | North       | 400                            | \$ _____                       |

**16ITB103233C-GS Generator System Maintenance and Repair Services  
Addendum No. 3**

| <b>I No</b> | <b>Building Number</b> | <b>Building Name</b>   | <b>Zone</b> | <b>Generator Size (kW/kVA)</b> | <b>Annual Maintenance Cost</b> |
|-------------|------------------------|--|-------------|--------------------------------|--------------------------------|
| 20          | B374012                | Helene S. Mills Senior Multipurpose Center, 515 John Wesley Dobbs Ave., Atlanta GA 30312 | Central     | 450                            | \$ _____                       |
| 21          | B316023                | Adamsville Regional Health Center, 3700 Martin Luther King Jr Drive, Atlanta GA 30313    | South       | 40                             | \$ _____                       |
| 22          | B400012                | Central Library, 1, Margaret Mitchell Sq   | Central     | 156                            | \$ _____                       |
| 23          | B303052                | D.A.Pearson Maint. Buildings, 3929 Aviation Circle                                       | North       | 15                             | \$ _____                       |
| 24          | B606022                | FAA Buildings, 3977 Aviation Circle  | North       | 31.3                           | \$ _____                       |
| 25          | B119012                | Fire Station # 19, 3965 Aero Dr  | North       | 10                             | \$ _____                       |
| 26          | B601011                | North Fulton Service Center, 7741 Roswell Road   | North       | 56                             | \$ _____                       |
| 27          | B111012                | Fire Station # 11, 4760 Fulton Industrial Blvd   | South       | 5                              | \$ _____                       |
| 28          | B103013                | Fire Station # 3, 4035 Stonewall Tell Rd   | South       | 20                             | \$ _____                       |
| 29          | B602013                | South Fulton Service Center, 5600 Stonewall Tell Rd                                      | South       | 56                             | \$ _____                       |
| 30          | B815013                | Medical Examiner's Office, 430 Pryor Street, Atlanta GA 3003                             | Central     | 280                            | \$ _____                       |
| 31          | B815013                | Medical Examiner's Office, 430 Pryor Street, Atlanta GA 3003                             | Central     | 280                            | \$ _____                       |
| 32          | B101013                | Fire Station # 1, 5265 Welcome All Road  | South       | 35                             | \$ _____                       |
| 33          | B107013                | Fire Station # 7, 5965 Buffington Road   | South       | 35                             | \$ _____                       |
| 34          | B606012                | Fulton County Airport, 3952 Aviation Circle  | North       | 150                            | \$ _____                       |

Fulton County reserves the right to add to and/or delete from, the list of generators included for maintenance.

Please quote price for any repair work not covered by Paragraph 6. **Product/Service Specifications.**

We quote:

35. \$ \_\_\_\_\_ Per trip as trip charges. Trip charges when allowed will be paid only once in a day

36. \$ \_\_\_\_\_ Per hour - Normal\* hours of operation

**16ITB103233C-GS Generator System Maintenance and Repair Services  
Addendum No. 3**

37. \$ \_\_\_\_\_ Per hour – Other than normal hours, weekends & Fulton County holidays

**ACKNOWLEDGEMENT OF ADDENDUM NO. 3**

The undersigned Bidders acknowledges receipt of this Addendum by returning one (1) copy of this form with the bidder's submittal package to the Department of Purchasing & Contract Compliance, Fulton County Public Safety Building, 130 Peachtree Street, S.W., Suite 1168, Atlanta, Georgia 30303 by Wednesday, August 3, 2016 at 11:00 A.M.

This is to acknowledge receipt of Addendum No. 3 \_\_\_\_\_ day of \_\_\_\_\_, 2016.

\_\_\_\_\_  
Legal Name of Bidder

\_\_\_\_\_  
Signature of Authorized Representative

\_\_\_\_\_  
Title