



DEPARTMENT OF PURCHASING & CONTRACT COMPLIANCE

**Winner 2000- 2008 Achievement of Excellence in Procurement Award
National Purchasing Institute**

Jerome Noble, Director



December 2, 2008

Re: #08ITB64423K-JD-10th Floor Terraces Waterproofing

Dear Bidders:

Attached is one (1) copy of Addendum 3, hereby made a part of the above referenced #08ITB64423K-JD-10th Floor Terraces Waterproofing.

Except as provided herein, all terms and conditions in the **#08ITB64423K-JD-10th Floor Terraces Waterproofing** referenced above remain unchanged and in full force and effect.

Sincerely,

Joyce Daniel

Joyce Daniel, CPPB
Assistant Purchasing Agent

#08ITB64423K-JD-10th Floor Terraces Waterproofing
Addendum No. 3
Page Two

This Addendum forms a part of the contract documents and **modifies** the original RFP documents as noted below:

Response to questions:

Question: Does the waterproofing membrane have to be a hot applied system or can we substitute with a different type of system. Please advise.

Response: Bidder must assume the use of the hot applied waterproof membrane system that has been specified. Use of alternate systems will not be allowed.

Information Regarding Drawings

There are no changes to drawings. All bidders are to check with Action Blue to ensure that they have the correct set of drawings.

ACKNOWLEDGEMENT OF ADDENDUM NO. 3

The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the proposal package to the Purchasing Department, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by the ITB due date and time **Monday, December 8, 2008, 11:00 A.M.**

This is to acknowledge receipt of Addendum No. 3, _____ day of _____, 2008.

Legal Name of Bidder

Signature of Authorized Representative

Title