



Fulton County, GA

# Department of Purchasing & Contract Compliance

Cecil S. Moore, CPPO, CPPB, CPSM, C.P.M., A.P.P  
Director

December 9, 2009

Re: 10ITB71094K-DB; Fuel Dispenser Replacement

Dear Vendors

Attached is one (1) copy of Addendum 2, hereby made a part of the above referenced ITB. Except as provided herein, all terms and conditions in the ITB referenced above remain unchanged and in full force and effect.

Please be advised the **Site Visit** for this project is **not** mandatory but is highly encouraged.

Sincerely,



Darlene A. Banks, CPPB  
Assistant Purchasing Agent

Winner 2000 - 2009 Achievement of Excellence in  
Procurement Award • National Purchasing Institute



**NOTE: The information below is to be incorporated & included as part of the Bid document**

**Delete:** 1.3.5., under Intent on page 121 of Specifications

**Delete:** 1.3.6., under Intent on page 121 of Specifications

**Change:** 3.4.3, under Scope of Work on page 125 should read "Black or silver corrosion-resistant side panels."

**Change:** 3.4.8, under Scope of Work on page 125 should read "Nominal dimensions must be for a High Hose mounts/hangers (see 1.3.1)."

**Change:** 3.5.1.1.2, under Scope of Work on page 125, the entire section should only read "Spill prevention must be included to facilitate spill resistance during the change of the filter."

**Change:** 3.6.1 and 3.7.1, under Scope of Work on page 126, change "UL Class 1, Division 1 to read UL Class 1, Division 2."

**Delete:** 3.7.1.4, under Scope of Work on page 127, delete in its entirety.

**Question:** I went to visit the Central Maintenance location for the dispenser replacement bid. I found that on the lower dispensing island which is in the back of the property there is also a kerosene dispenser that is not on the bid sheet information. Is this one to be replaced at this time or at a later date? Also, it appears that all the dispensers are suction and on the list it mentions that one of the unleaded is a submerged. Please let me know so that we can properly bid this project.

**Response:** The kerosene dispenser is **not** included in this bid. Also, one of the unleaded is a submerged type pump.

**Clarification:** There are a total of eight site locations. Please remember this when completing the Price Information Sheet. Two (2) site locations are at Central Maintenance Facility; one upstairs and one downstairs.

## ACKNOWLEDGEMENT OF ADDENDUM NO. 2

The undersigned bidder acknowledges receipt of this addendum by returning one (1) copy of this form with the bid package to the Purchasing & Contract Compliance Department, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by Thursday, December 17, 2009 at 11:00am.

This is to acknowledge receipt of Addendum No. 2, \_\_\_\_\_ day of \_\_\_\_\_, 2009.

\_\_\_\_\_  
Legal Name of Bidder

\_\_\_\_\_  
Signature of Authorized Representative

\_\_\_\_\_  
Title

Winner 2000 - 2009 Achievement of Excellence in  
Procurement Award • National Purchasing Institute

