



DEPARTMENT OF PURCHASING & CONTRACT COMPLIANCE

**Winner 2000- 2006 Achievement of Excellence in Procurement Award
National Purchasing Institute**

Jerome Noble, Director



February 19, 2008

Re: Bid # 08ITB59460K-DJ W032 Pritchard Mountain Elevated Water Tank

Dear Bidders:

Attached is one (1) copy of Addendum 2, hereby made a part of the above referenced Invitation to Bid # 08ITB59460K-DJ W032 Pritchard Mountain Elevated Water Tank.

The bid due date for this project is Monday, February 25, 2008 at 11:00 AM. This Addendum forms a part of the contract documents and modifies the original documents as noted below.

Except as provided herein, all terms and conditions in the Invitation to Bid referenced above remain unchanged and in full force and effect.

Sincerely,

Donna Jenkins

Donna Jenkins,
Chief Assistant Purchasing Agent

See attached documents

ADDENDUM No. 2

Modifications to the Specifications

- Item 1 Section 00300 Bid Form, under CASH ALLOWANCES, Item 6 – Mixing System Allowance, delete “\$45,000” and replace with “\$100,000”.
- Item 2: Section 13210 Composite Elevated Water Storage Tank, page 1 of 26, Article 1.02B; delete the elevations shown and replace with the following:
- | | |
|---------------------------------|---------------------|
| <i>“Elevation – grade slab</i> | <i>1238.50 feet</i> |
| <i>Elevation – final ground</i> | <i>1238.0 feet”</i> |

Modifications to the Drawings

- Item 1 Sheet C6.0 Water Tank Details; on the right side of the page delete the top of foundation elevation (shown as 1238.0) and replace with “*El. 1238.50*”

Questions and Responses:

- Question 1 Drawing C8.0 shows top of foundation elevations of 1238.00 while page 1 of spec section 13210 calls for "Grade Slab" elevation of 1240.50 with final grade at 1240.00. Which elevations are correct?
- Response** See Modifications to Specifications, Item 2 and Modifications to Drawings, Item 1.
- Question 2 Spec Section 13210, page 9, paragraph 2.04E calls for a roof conical in shape of a "flat domed roof with a 2'-6" pressed knuckle". The CB&I standard roof design is a dome like the last ones we built for Fulton County at the North Fulton site. Is CB&I's standard dome roof design acceptable?
- Response** Yes.

ACKNOWLEDGEMENT OF ADDENDUM NO. 2

The undersigned bidder acknowledges receipt of this addendum by returning one (1) copy of this form with the proposal package to the Purchasing Department, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30335 by the Bid due date and time on **Monday, February 25, 2008 at 11:00 A.M.**

This is to acknowledge receipt of Addendum No. 2, _____ day of _____, 2008.

Legal Name of Bidder

Signature of Authorized Representative

Title