


Atlanta Fulton County Public Library System – Alpharetta Public Branch



**Addendum #1
11/12/14**



Contents

Questions:

RFI-1) Can you please supply more detail regarding items 703 – 714. Are we to supply materials only? If we are to install, can you please provide installation instructions or more info regarding what is needed?

Answer – This material is furnished and installed. The shelving is standard Metal Estey Product from Tennsco. Canopy support brackets will be provided with single screw on each side, and you can screw through the center std in to the back of end panels.

RFI-2) Signage type 10.5 indicated 1 (ea) on the signage counts but can not be found on drawings. Should we include 10.5 in the pricing?

Answer – Yes include signage 10.5 per the signage counts.

End of Addendum1