



DEPARTMENT OF PURCHASING & CONTRACT COMPLIANCE

**Winner 2000- 2006 Achievement of Excellence in Procurement Award
National Purchasing Institute**



Jerome Noble, Director

October 11, 2007

Re: 07RFP57405K-RS, Big Creek Water Reclamation Facility Membrane System Technology

Dear Proposers:

Attached is one (1) copy of Addendum 5, hereby made a part of the above referenced Request for Proposal (RFP).

Except as provided herein, all terms and conditions in the RFP referenced above remain unchanged and in full force and effect.

Sincerely,

Rholanda M. Stanberry

Rholanda Stanberry,
Chief Assistant Purchasing Agent

Questions and Responses:

Item No.	Section	Page No.	Wording in question
TC-1	11183	4	2.03 B Electrical requirements Motors Rating - 460V
			Question Please confirm that for blowers with HP greater than 700 HP, 2300 to 4500 voltage is acceptable.
			Response Motors greater than 500 HP shall be 4160 volts.

ACKNOWLEDGEMENT OF ADDENDUM NO. 5

The undersigned bidder acknowledges receipt of this addendum by returning one (1) copy of this form with the bid package to the Purchasing Department, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30335 by the Bid due date and time on **Monday, October 29, 2007** at 11:00 A.M.

This is to acknowledge receipt of Addendum No. 5, _____ day of October, 2007.

Legal Name of Bidder

Signature of Authorized Representative

Title