



Fulton County, GA

Department of Purchasing & Contract Compliance

May 24, 2013

Re: **13ITB88425C-DR, LOCKS, DOOR HARDWARE & LOCKSMITH SERVICES**

Dear **Bidder(s)**:

Attached is one (1) copy of Addendum 1, hereby made a part of the above referenced **13ITB88425C-DR, Locks, Door Hardware & Locksmith Services**.

Except as provided herein, all terms and conditions in the **13ITB88425C-DR** referenced above remain unchanged and in full force and effect.

Sincerely,

Donald R. Riley

**Donald R. Riley, CPPB
Assistant Purchasing Agent**

Winner 2000 - 2009 Achievement of Excellence in
Procurement Award • National Purchasing Institute



13ITB88425C-DR, LOCKS, DOOR HARDWARE & LOCKSMITH SERVICES

Addendum No. 1

Page Two

This Addendum forms a part of the contract documents and modifies the original ITB documents as noted below:

1. Questions are attached for all bidders to review before submittal of their responses.
2. Due date has been extended until June 5, 2013 at 11:00 am est.

For additional information regarding this addendum, contact Donald R. Riley, Assistant Purchasing Agent at (404) 612-7916.

Except as provided herein, all terms and conditions in the bid referenced above remain unchanged and in full force and effect.

Failure to return a signed copy of this addendum could render your bid non-responsive.

ACKNOWLEDGEMENT OF ADDENDUM NO. 1

The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the proposal package to the Department of Purchasing & Contract Compliance, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by the ITB due date and time **June 5, 2013, at 11:00 A.M.**

This is to acknowledge receipt of Addendum No. 1, _____ day of _____, 20__.

Legal Name of Bidder

Signature of Authorized Representative

Title

13ITB88425C-DR, LOCKS, DOOR HARDWARE & LOCKSMITH SERVICES
Addendum No. 1
Page Three

- (1) Line 4 Push-button combination locks: The model number is incomplete. We need to know which manufacturer's IC cores are required to fit into the Simplex lock. There are multiple options: Corbin Russwin, Best, Sargent, Medeco, Yale and others. You must also specify a finish. Would you please give us a complete model number of the type lock for which you wish to have a price?

Response: The lock will be used with Corbin Russwin IC cores, Chrome Finish,

- (2) Is a bid bond required for this project?

Response: For this project, Fulton County does not require a bid bond for this project.

- (3) Line 5 Sargent door locks 8255: The model number is incomplete. There are many options including lever design, function, finish of lockset just to name a few. Would you please give us a complete model number of the type lock for which you wish to have a price?

Response: Handle design, class room function, Bronze finish, Office or Entry key

- (4) Line 6 Sargent Door locks 7855: There are many options including knob design, function, finish of lockset just to name a few. Would you please give us a complete model number of the type lock for which you wish to have a price?

Response: Handle design, class room function, Polished chrome finish, Office or Entry key

- (5) Line 7 Key blanks: Schlage: The model number is incomplete. There are many different types of key blanks. Would you please give us a complete model number of the type lock for which you wish to have a price?

Response: SC1 for common Schlage 5-pin classic C keyway

- (6) Line 8 Key blanks – Sargent: The model number is incomplete. There are many different types of key blanks. Would you please give us a complete model number of the type lock for which you wish to have a price?

Response: Standard Sargent -LA- Keyway 6-pin. Brass key blanks S22

- (7) Line 9 Schlage L9485L: The model number is incomplete. Would you please give us a complete model number of the type lock for which you wish to have a price?

- (8) **Response:** L Ser Hotel L/ Ffc 07b 629 Lh #L9485L 07B 629 LH — SCHLAGE

(9) Line 10 Von Duprin Panic exit device Type 22 EO rim device: The model number is incomplete. We don't know the length of the device or the finish. Would you please give us a complete model number of the type lock for which you wish to have a price?

Response: Von Duprin 2227L-F Fire Rated Vertical Rod Device W/ 230L Lever Trim, No Cylinder, 3 Ft, SP 313, Dark Bronze

(10) Line 11 Corbin Russwin ED5200SA Series Security Deadbolt rim fire exit devices: The model number is incomplete. Would you please give us a complete model number of the type lock for which you wish to have a price?

Response: ED5200SA 3 Hr. 4' x 8' opening, Surface applied; single-point latching!

(11) Line 12: Corbin Russwin ED 8400 Series surface vertical rod exit device. The model number is incomplete. Would you please give us a complete model number of the type lock for which you wish to have a price?

Response: ED8400 x ED8400 , Panic 1-1/2 Hr. UL 8' x 10' 2 independent doors with 2 point latching, swinging in the same direction. Overlapping astragal may not be required.

(12) What type license is required? (form C: Ga professional license certification)

Response: There are no license(s) required for this project place n/a on the Form C.