



DEPARTMENT OF PURCHASING & CONTRACT COMPLIANCE

**Winner 2000- 2006 Achievement of Excellence in Procurement Award
National Purchasing Institute**

Jerome Noble, Director



June 27, 2007

Re: 07ITB56368K-RS Mid Broadwell Petition Sewer

Dear Bidders:

Attached is one (1) copy of Addendum 1, hereby made a part of the above referenced Bid #07ITB56368K-RS Mid Broadwell Petition Sewer.

This Addendum forms a part of the contract document and modifies the original Bid documents as noted below:

Except as provided herein, all terms and conditions in the Bid referenced above remain unchanged and in full force and effect.

Sincerely,

Rholanda M. Stanberry

Rholanda Stanberry,
Chief Assistant Purchasing Agent

Corrections to Drawings:

Sheet C-403: Remove “x” out for Detail 2 in upper right quadrant of sheet and add the following note to the detail.

Contractor shall use Type “C” repair detail for this project. Paving shall be full width of roadway.

Question: Drawing No C-201 shows that we need to use detail (2/C-403). When referred to this detail on page C-403, it’s crossed out. What type of ditch cap, Fulton County would like to install over the proposed sewer line? Please clarify.

Response: Use Type C repair detail in Section 2 on Sheet C-403. See “Corrections to Drawings” above.

ACKNOWLEDGEMENT OF ADDENDUM NO. 1

The undersigned bidder acknowledges receipt of this addendum by returning one (1) copy of this form with the bid package to the Purchasing Department, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30335 by the Bid due date and time on Monday, July 2, 2007 at 11:00 A.M.

This is to acknowledge receipt of Addendum No. 1, _____ day of _____, 2007.

Legal Name of Bidder

Signature of Authorized Representative

Title