



Fulton County, GA

Department of Purchasing & Contract Compliance

June 27, 2014

Re: 14ITB93488C-DR, Standby Asphalt Paving, Concrete & Masonry Repairs

Dear Bidder's:

Attached is one (1) copy of Addendum 1, hereby made a part of the above referenced **14ITB93488C-DR, Standby Asphalt Paving, Concrete & Masonry Repairs.**

Except as provided herein, all terms and conditions in the **14ITB93488C-DR** referenced above remain unchanged and in full force and effect.

Sincerely,

Donald R. Riley

Donald R. Riley, CPPB
Assistant Purchasing Agent

Winner 2000 - 2009 Achievement of Excellence in
Procurement Award • National Purchasing Institute



14ITB93488C-DR, Standby Asphalt Paving, Concrete & Masonry Repairs

Addendum No. 1

Page Two

This Addendum forms a part of the contract documents and modifies the original ITB documents as noted below:

See the attached document for clarification responses to the questions received.

For additional information regarding this addendum, contact Donald R. Riley, CPPB, Assistant Purchasing Agent at (404) 612-7916.

Except as provided herein, all terms and conditions in the bid referenced above remain unchanged and in full force and effect.

Failure to return a signed copy of this addendum could render your bid non-responsive.

ACKNOWLEDGEMENT OF ADDENDUM NO. 1

The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the proposal package to the Department of Purchasing & Contract Compliance, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by the ITB due date and time **July 9, 2014, @ 11:00 A.M.**

This is to acknowledge receipt of Addendum No. 1, _____ day of _____, 20__.

Legal Name of Bidder

Signature of Authorized Representative

Title

1. On page 13 Item 2: How thick is the concrete?.

Response: Item 2 will be 8" concrete repair and removal; Saw cutting and reworking subgrade (item 12) are not included. This is the same as Item 8 except it is 8" thick concrete.

2. On page 14 Item 3: Is the price of the overlay to include 1" of permafex and 1" of type F asphalt?

Response: Yes. The price of the overlay is to include the 1" of permafex and 1" of type F asphalt.

3. On page 17 Item 13A: how thick is the Asphalt that is to be milled out?

Response: Two prices; one for 1"-2" milled and second price for 3"-4" milled

4. On page 18 Item: 17: What type of red brick, ADA or Plain Decorative Brick?

Response: Plain decorative brick.

5. On page 18 Item: 17: What size of crane truck are you asking for?

Response: The County is requesting a 2 ton crane truck for this solicitation.

6. On page 18 Item: 17: What size steel plates will be needed?

Response: For this solicitation the County will require 4 x 5 steel plates

7. On page 18 Item: 17: Can a skid steer but instead of a loader/backhoe?

Response: For this solicitation a skid steer maybe used instead of a loader/backhoe.