



## Department of Purchasing

**Felicia Strong-Whitaker, CPPO**  
Director

Suite 1168  
130 Peachtree Street, S.W.  
Atlanta, GA 30303  
[www.fultoncountyga.gov](http://www.fultoncountyga.gov)

Main: (404) 612-5800

May 27, 2015

**Re:** 15FB97838C, Underground Storage Tank In-Place Closure At The Central Maintenance Facility

Dear Bidders:

Attached is one (1) copy of Addendum 1, hereby made a part of the above referenced Quote.

Except as provided herein, all terms and conditions in the Quote referenced above remain unchanged and in full force and effect.

Sincerely,

*Felicia Brooks*  
*Procurement Officer*

**15FB97838C, Underground Storage Tank In-Place Closure At The Central  
Maintenance Facility**

**Addendum No. 1**

**Page Two**

This Addendum forms a part of the contract documents and **modifies** the original Quote documents as noted below:

- Attached Question(s) submitted for clarification
- **The RFQ due date and time has been extended to June 1, 2015 2:00 PM**

**ACKNOWLEDGEMENT OF ADDENDUM NO. 1**

The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the proposal package to the Department of Purchasing & Contract Compliance, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by the Quote due date and time **June 1, 2015, 2:00 P.M.**

This is to acknowledge receipt of Addendum No. 1, \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_.

\_\_\_\_\_  
Legal Name of Bidder

\_\_\_\_\_  
Signature of Authorized Representative

\_\_\_\_\_  
Title

**15FB97626C, Underground Storage Tank In-Place Closure At The Central  
Maintenance Facility**

**Addendum No. 1**

**Page Three**

Attachment#1

Question(s) submitted for Clarification

**Question #1: Please confirm how many, size, and former product content of USTs to be closed in place?**

Answer: 5 Underground Storage Tanks and 1 Above Ground Storage Tank: Three (3) 2,000 gallon contained oil, One (1) 4,000 gallon contained antifreeze and One (1) 2,000 gallon contained kerosene

**Question #2: Does in-place closure include the removal of all above ground piping and supports associated with vent piping, including 20+ feet of vent piping attached to the building?**

Answer: Yes

**Question #3: Please confirm that the scope of work for removal includes removing the above ground storage tank (1,000-gallon poly) and all equipment from the car wash building.**

Answer: Yes

**Question #4: Will the kerosene dispenser require removal?**

Answer: Yes

**Question #5: In accordance to GA EPD regulations a piping soil sample will be required for every 25 feet of product piping. Please confirm access to advance boreholes near piping run from 4 USTs into the building.**

Answer: Yes

**Question #6: Does the required Safety Plan to be included with the quote need to be a site specific developed plan or is a generic plan pertaining to UST closure sufficient?**

Answer: The contractor should have a safety plan that satisfies due diligence under OSHA and GA EPD regulations.

**15FB97626C, Underground Storage Tank In-Place Closure At The Central  
Maintenance Facility**

**Addendum No. 1**

**Page Four**

**Question #7: Is fence relocation included in the unit pricing a part of the scope of work?  
If so, please provide additional information.**

Answer: Fencing was mentioned in error. It is not a part of this procurement.

**Question #8: Unit pricing Line #3 reads as if 20 USTs are being closed in place, please  
clarify.**

Answer: Only 5 UST and 1 AUT

**Question #9: Were the pumps utilized for the USTs located at the USTs or near the  
dispensers?**

Answer: The kerosene is at the dispenser. The others are inside the building.

**Question #10: Can schematics of the UST systems and building utilities be provided to  
the successful bidder?**

Answer: Yes