



Fulton County, GA

Department of Purchasing & Contract Compliance
Cecil Moore, Director

March 1, 2012

Re: #12ITB10729YC-AP, HVAC SECURITY CAGES AND ALARMS

Dear Proposers:

Attached is one (1) copy of Addendum 7 hereby made a part of the above referenced Invitation to Bid.

Except as provided herein, all terms and conditions in the Invitation to Bid referenced above remain unchanged and in full force and effect.

Sincerely,

Al Micah Phillips
Assistant Purchasing Agent

Addendum No. 7
Page Two

This Addendum forms a part of the contract documents and **modifies** the original Bid documents as noted below:

The following information is a requirement for Bidders:

1). Response to Questions received on bid 12ITB10729YC-AP, HVAC Security Cages and Alarms.

Proposal Questions:

1. We would like to review any and all invoices from your current vendor (Cage it Up) and another Company titled "Cypress" that did the install of Security in October of 2011 at New Beginning Neighborhood Senior Center
This action was not handle The Purchasing Dept.
2. We would also like to review all invoices for Security Cages installed at Springdale Road Facility. This action was not handle The Purchasing Dept.
3. We need to see a sample of the Expanded Metal that Fulton County now wants to use, in the Pre-Bid conference of last week it was sated that the expanded is now changed to 12 gauge we need to see this type of product.
There has been no change in the size of the expanded metal from the original specification.
4. Green paint was asked to be used what is the PMS color green you would like to use. If you want to use black paint what PMS color of black do you want to use, is there a sample available to view.
PMS Color matching is not generally used for industrial protective coatings. This was not specified in the package and is not applicable.
5. Will there be Mandatory Insurance requirement. Yes. This is specified in the bid package.
6. Because there will be Metal and Steel Fabrications on this project or you asking for Certified Welder's Certificate and Certified Fabricator. Fulton County is not asking for certificate from Certified Welders or Certified fabricators.
7. Will this project OSHA PPE certification (Personal Protective Equipment) You may use OSHA PPE for protection of your personnel, but Fulton County does not have any opinion in this matter. Please check with your insurance company.
8. What are your specifications for the lock fixture for which GSD will provide all locks for?
Fulton County will buy necessary locks.
9. There now needs to be added to GSD specification that on all Roof type building that 2"x 4" board be use to support the base of the Metal legs against the
This is noted, but will be reviewed on a case to case basis for each installation.

I would like some clarification of section 1.7(Security Alarm System)

(1) 1.7.2 States that the security system should have (2) horns, the alarm panel comes with one. Do you need an extra horn per panel installed, and can the horn that comes with the watch dog panel be used? There shall be one horn for the power disconnect and another for the low pressure switch. The horn that comes with the Watch Dog can be used if the sound level generated is between 100 dB and 115dB.

(2) 1.7.4. States that the security alarm system is to be wired into the fire alarm panel of the building, who is responsible for performing this task, Wiring up to the fire alarm panel is contractor's responsibility. Actual connection to the panel will be made by Fulton County staff.

It also states that the alarm will be tested by releasing some Freon. This is against the EPA Regulations. The same results can be accomplished by disconnecting the pressure switch.

Releasing the pressure also checks the response of the pressure switch. Freon can be discharged in to a container, to comply with EPA regulations.

*Please clarify if the wall and window units will be alarmed.
No. Cages and alarms will not be used for wall units.*

ACKNOWLEDGEMENT OF ADDENDUM NO. 7

The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the proposal package to the Purchasing Department, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by the Bid due date and time **March 7, 2012 at 11:00 A.M.**

This is to acknowledge receipt of Addendum No. 7, _____ day of _____, 2012.

Legal Name of Bidder

Signature of Authorized Representative

Title