



DEPARTMENT OF PURCHASING & CONTRACT COMPLIANCE

**Winner 2000- 2006 Achievement of Excellence in Procurement Award
National Purchasing Institute**

Jerome Noble, Director



January 30, 2008

Re: Bid # 071TB58420K-RS Riverside Road Pump Station Upgrade

Dear Bidders:

Attached is one (1) copy of Addendum 6, hereby made a part of the above referenced Invitation to Bid # 071TB58420K-RS Riverside Road Pump Station Upgrade.

The bid due date for this project is Monday, February 11, 2008 at 11:00 AM. This Addendum forms a part of the contract documents and modifies the original documents as noted below.

Except as provided herein, all terms and conditions in the Invitation to Bid referenced above remain unchanged and in full force and effect.

Sincerely,

Donna Jenkins

Donna Jenkins,
Chief Assistant Purchasing Agent

See attached documents

ADDENDUM No. 6

This project has been extended; the new due date is Monday, February 11, 2008

Modifications to the Specifications

- Item 1: Section 16620, PARAGRAPH 2.05 A., Change the words "480VAC" to "4160VAC".

ACKNOWLEDGEMENT OF ADDENDUM NO. 6

The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the proposal package to the Purchasing Department, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30335 by the Bid due date and time on **Monday, February 11, 2008 at 11:00 A.M.**

This is to acknowledge receipt of Addendum No. 6, _____ day of _____, 2008.

Legal Name of Bidder

Signature of Authorized Representative

Title