



DEPARTMENT OF PURCHASING & CONTRACT COMPLIANCE

**Winner 2000- 2007 Achievement of Excellence in Procurement Award
National Purchasing Institute**

Jerome Noble, Director



April 4, 2008

**Re: 08ITB60690K-DB
S110 Marsh Creek Sewer Rehabilitation**

Dear Bidders:

Attached is one (1) copy of Addendum 2, hereby made a part of the above referenced Bid #08ITB60690K-DB, S110 Marsh Creek Sewer Rehabilitation.

Except as provided herein, all terms and conditions in the Bid #08ITB60690K-DB; S110 Marsh Creek Sewer Rehabilitation referenced above remain unchanged and in full force and effect.

Sincerely,

Darlene A. Banks, CPPB
Assistant Purchasing Agent

**08ITB60690K-DB
S110 Marsh Creek Sewer Rehabilitation
Addendum No. 2
Page 2 of 4**

This Addendum forms a part of the contract documents and modifies the original Bid documents as noted below:

Modifications to Insurance Requirements

- Item 1 Section 00490, Insurance Information/Requirements, page 1, under item 5, Umbrella Policy, change “\$10,000,000” to “\$5,000,000” . ,
- Item 2 Section 00490, Insurance Information/Requirements, page 2, under item 8, Fidelity Bond, change “\$100,000” to “Not Required”.

Modifications to Specifications:

- Item 1 Section 02731, Sewer Rehabilitation, page 10 of 26, in the first paragraph under 2.04A, delete the last line of the paragraph and replace with the following: “Acceptable Level C products shall be Spraywall or Sprayshield by Sprayroc, Inc. or SpectraShield.”

Questions and Responses:

1. **QUESTION:** Why do we need a Fidelity Bond?

RESPONSE: A Fidelity Bond will not be required. See item 2 in **Modifications to Insurance Requirements** above.

2. **QUESTION:** Is the Builders Risk required?

RESPONSE: Yes.

3. **QUESTION:** Does Umbrella have to be \$10,000,000.00?

RESPONSE: Amount is reduced, per this addendum, to **\$5,000,000**. See item 1 in **Modifications to Insurance Information/Requirements** above.

08ITB60690K-DB
S110 Marsh Creek Sewer Rehabilitation
Addendum No. 2
Page 3 of 4

4. **QUESTION:** Does Workers Compensation have to be \$1,000,000.00?

RESPONSE: Yes.

5. **QUESTION:** the access to this project is extremely difficult in places, would the County consider adding a cash allowance for this item as the costs for this are almost undeterminable?

RESPONSE: No.

6. **QUESTION:** There are several times that the bypass will need to cross the creek. While the invitation to bid states "no permits or easements have been secured, as this work is considered maintenance work in existing County easements and rights-of-way." Will this be the case for the creek crossings?

RESPONSE: Contractor may utilize existing easement where sewer crosses the creek as long as work is in compliance with State regulations.

7. **QUESTION:** Is there an engineers' estimate for this project?

RESPONSE: Fulton County will not be releasing that information.

8. **QUESTION:** Could you restate in writing what forms subcontractors are required to submit as part of this bid document?

RESPONSE: As stated in the Bid document, each Prime Bidder/Contractor must include the following forms from subcontractors in their Bid: Section 00420, Purchasing Forms & Instructions, page 1, Form H: Georgia Security and Immigration Subcontractor Affidavit.

Section 00430, Contract Compliance Requirements, page 2, Exhibit A: Promise of Non-Discrimination (for Prime and each Subcontractor), Exhibit B: Employment Report (for Prime and each Subcontractor) and Exhibit D: Letter of Intent to Perform as a Subcontractor or Provide Materials or Services. Please review entire document before submitting. As a vendor it is your responsibility to submit and be in compliance with this Bid.

**08ITB60690K-DB
S110 Marsh Creek Sewer Rehabilitation
Addendum No. 2
Page 4 of 4**

9. **QUESTION:** Can SpectraShield be considered an acceptable product under Section 02731, Article 2.050K?

RESPONSE: No. It does not meet the requirement for cured in place manhole liner. However it will be accepted under Section 2.04 A, Spray on polymer manhole lining. See item 1 in **Modifications to Specifications** above.

ACKNOWLEDGEMENT OF ADDENDUM NO. 2

The undersigned bidder acknowledges receipt of this addendum by returning one (1) copy of this form with the bid package to the Purchasing Department, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by the Bid due date and time on Monday, April 14, 2008 at 11:00 A.M.

This is to acknowledge receipt of Addendum No. 2, _____ day of _____, 2008.

Legal Name of Bidder

Signature of Authorized Representative

Title