

BEND	PIPE SIZE (IN.)	"W" (FT.)	"L" (FT.)	"H" (FT.)	VOLUME (CY)
11 $\frac{1}{4}^{\circ}$	6	1.0	2.0	1.0	0.04
	8	1.0	2.0	1.0	0.05
	12	1.0	2.0	2.0	0.1
	16	2.0	3.0	2.0	0.3
	20	2.0	3.0	3.0	0.5
22 $\frac{1}{2}^{\circ}$	6	1.0	2.0	1.0	0.05
	8	1.0	2.0	2.0	0.1
	12	2.0	3.0	2.0	0.3
	16	2.0	4.0	3.0	0.6
	20	3.0	5.0	3.0	1.0
45°	6	1.5	2.0	1.5	0.11
	8	2.0	3.0	2.0	0.3
	12	2.0	4.0	3.0	0.7
	16	3.0	5.0	4.0	1.4
	20	4.0	8.0	5.0	2.8
90°	6	1.75	2.5	2.0	0.2
	8	2.0	3.0	3.0	0.4
	12	4.0	6.0	4.0	2.1
	16	4.0	7.0	5.0	3.1
	20	5.0	8.0	7.0	5.3

FULTON COUNTY STANDARD DETAIL 132B

STANDARD THRUST BLOCK DETAILS

DGS/DRN/CHKD:	MB/EB/ML
APPROVED:	TM
DATE:	02-18-2026



DRAWING NO.

132B