Fulton County is an Equal Opportunity Employer encouraging diversity. If you need reasonable modifications due to a disability, including communications in an alternate format, please contact (404) 612-7400 or PW.CustomerService@fultoncountyga.gov. For TDD/TTY or Georgia Relay Service access, dial 711.

NOTE:

1. DOMESTIC AND / OR IRRIGATION SERVICE TAPS SHALL BE MADE BY FULTON COUNTY BETWEEN VAULT AND R/W WITH METERS SET AT EDGE OF EASEMENT.
2. ALL SEWER LINES, WATER LINES, REUSE LINES, AND FORCE MAIN LINES SHALL HAVE 3M™ EMS WARNING TAPE 7900 SERIES BURIED 4-FEET BELOW GROUND LEVEL INSTALLED ABOUT THE PIPE OR MINIMUM OF 1-FOOT ABOVE TOP OF PIPE. THIS SHALL INCLUDE SEWER LATERALS AND WATER SERVICE LINES.



NOTE:
6" MIN. TAP FOR 3", 4" AND 6" METERS

LARGE METER
SHORTSIDE SERVICE
N.T.S.



LARGE METER
LONGSIDE SERVICE
N.T.S.

FULTON COUNTY STANDARD DETAIL 806 LARGE WATER METER LAYOUT		DATE	REVISIONS	DATE	REVISIONS	DGS/DRN/CHKD: MB/EB/ML APPROVED: TM DATE: 02-18-2026	FULTON COUNTY	FULTON COUNTY PUBLIC WORKS 141 PRYOR ST. ATLANTA, GA. 30303 404-612-7400 FAX: 404-224-0498	DRAWING NO. 806

806 – Large Meter Layout.dwg March 17, 2026 – 4:14pm