

1. FOR METERS 3 INCHES AND LARGER, VAULTS MAY BE ROTATED 90 DEGREES TO MINIMIZE PROJECTION INTO PROPERTY.
2. ALL METERS ON PRIVATE PROPERTY SHALL HAVE AN ACCESS AND MAINTENANCE EASEMENT THAT EXTENDS THREE FEET FROM EACH SIDE OF THE METER BOX / VAULT, EXCEPT BOXES FOR METERS 2 INCHES AND SMALLER MAY BE PLACED 6 INCHES FROM THE PROPERTY / RIGHT OF WAY LINE.
3. FOR SINGLE SERVICE DEVELOPMENT (COMMERCIAL, APARTMENTS ETC.) TAP, SERVICE LINE, METER SIZE, AND BACKFLOW DEVICE SHALL BE THE SAME.
4. FOR LONG SIDE 1 INCH SERVICE LINES, SERVICE LINES SHALL BE INSTALL IN 6 INCH PVC CONDUIT. TWO 1 INCH SERVICE LINES MAY BE INSTALLED IN ONE CONDUIT.
5. TAP, METER, AND BACKFLOW PROTECTION DEVICE MUST MATCH MAIN SIZE IN DEVELOPMENT.
6. IN THE EVENT CONDUIT IS NOT PRESENT ON LONG SIDE LOT, BORING SHALL BE PERMITTED. WHEN CONDUIT DOES EXIST, 1-IN. PIPE SHALL BE INSERTED THROUGH 6-IN. PVC CASING TO COMPLETE THE INSTALLATION FROM THE MAIN TO THE METER. 2-IN. HDPE CASING TO BE USED WHEN BORING.
7. APPROVAL MUST BE OBTAINED FROM THE CITY IN WHICH THE PROJECT IS LOCATED PRIOR TO ROAD CUT. THE PUBLIC WORKS WATER SERVICES DIVISION DOES NOT HAVE THE AUTHORITY TO APPROVE ROAD CUTS.
8. 48" COVER (MIN.) FROM SURFACE TO TOP OF SERVICE PIPE APPLIES TO COUNTY MAINTAINED ROADS. FOR STATE ROADS SAID MINIMUM CLEARANCE SHALL BE 54".
9. ALL CUTS IN PAVEMENT SHALL BE REPAIRED IN ACCORDANCE WITH EITHER GA..D.O.T OR FULTON CO. STANDARDS. CONTRACTOR SHALL BE RESPONSABLE FOR PROPER DITCH COMPACTION, CUT BACK OF DITCH SIDES AND PAVING OF THE REQUIRED CONCRETE SUB-BASE AND PLATING THE DITCH TO ALLOW TRAFFIC FLOW WHILE CONCRETE IS SETTING UP. STEEL TRAFFIC PLATES WILL COVER POURED CONCRETE FOR A MINIMUM OF 24 HOURS.
10. METERS ARE TO BE SET DIRECTLY OPPOSITE AND AT RIGHT ANGLES TO TAP ON MAIN. THE METER SHALL NOT BE OFFSET Laterally FROM TAP ON WATER MAIN.

FULTON COUNTY STANDARD DETAIL 807 GENERAL NOTES FOR METER INSTALLATION		DATE	REVISIONS	DATE	REVISIONS	DGS/DRN/CHKD: MB/EB/ML		FULTON COUNTY PUBLIC WORKS 141 PRYOR ST. ATLANTA, GA. 30303 404-612-7400 FAX: 404-224-0498	DRAWING NO. 807
						APPROVED: TM			
						DATE: 02-18-2026			