


**METER BOX**

- MODIFIED POLYETHYLENE METER BOX SHALL HAVE NOMINAL DIMENSIONS OF 19-1/2" X 12-3/8" X 18" AND SHALL HAVE A 10,000 LB. LOAD RATING WITH A SINGLE MOUSE HOLE IN EACH END. COVER FOR METER BOX SHALL BE MODIFIED POLYETHYLENE WITH "WATER METER" IN MINIMUM 1" HIGH LETTERS. LIDS SHALL HAVE OBLONG KNOCK OUT AND 1/2-INCH RECESS FOR METER ANTENNAE WITH A FERROUS MAGNET IN THE LID AND A PLASTIC LOCKING MECHANISM. THE COVERS SHALL HAVE A NON-SKID SURFACE. METER BOX AND LID SHALL BE DFW METER BOX MODEL 1219-18-1MKF DEEP. LID ONLY SHALL BE MODEL 1219-1-MKF DEEP.
- LID FOR STRETCH YOKE BOX SHALL BE DFW MODEL 6514-1-MKF DEEP WITH OBLONG KNOCK OUT AND 1/2-INCH RECESS FOR METER ANTENNAE WITH A FERROUS MAGNET IN THE LID AND A PLASTIC LOCKING MECHANISM.

<p>FULTON COUNTY STANDARD DETAIL 801 5/8" AND 3/4" METER INSTALLATION</p>	DATE	REVISIONS	DATE	REVISIONS	<p>DGS/DRN/CHKD: CMS APPROVED: REW DATE: 12-2-05</p>	 <p>FULTON COUNTY PUBLIC WORKS 141 PRYOR ST. ATLANTA, GA. 30303 404-612-7400 FAX: 404-224-0498</p>	DRAWING NO. 801
	15/08	NRR					
	1/18	TPM					